



Jim Doyle, Governor
Jack L. Fischer, A.I.A., Secretary

March 26, 2008

LAKE SHORE BURIAL VAULT CO., INC.
HUBERT MCQUESTION
12780 LISBON ROAD
BROOKFIELD WI 53005

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)
Manufacturer: LAKE SHORE BURIAL VAULT CO., INC.
Product Name: BIO-MICROBICS MICRO FAST
Model Number(s): 2450
(0.5, 0.75 or 0.9 MICRO FAST)
Product File No: 20080147

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of JUNE 2013.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The capacity of the sedimentation tank is exempt from the minimum capacity requirements of s. Comm 83.15 (3) of the Wis. Admin. Code. This tank capacity must not be included in the septic tank capacity required by s. Comm 83.15 (3) of the Wis. Admin. Code.
- This product must be installed in accordance with the manufacturer's printed instructions, product approval and the plan approval. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval will take precedence.
- A sedimentation tank or compartment with a minimum capacity of 500 gallons must be located upstream of the tank or compartment in which the 0.9 Bio-Microbics unit is installed.
- The distance from top of tank cover to centerline of pipe outlet for the Bio-Microbics treatment unit must be 15 inches.

This approval supersedes the approval issued on 10/15/2007 under product file number 20070448. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20070448.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov

SBD-10564-E (N.10/97)

File Ref: 08014701.DOC